



# MP-Bus Data-Pool Values

MP  BUS

## Flow Sensor 22PF-.. / V4.3.0

Edition 2026-05

  
**BELIMO**<sup>®</sup>

# Table of contents

## General notes

---

General information	
Identification	
Configuration	3
Timing of MP-Bus queries	
Signed integer	

## Values overview

---

Operation	4
Configuration	

## Values descriptions

---

Flow	5
Temperature	6
Conversion of sensor signals	
Health state	7

# General notes

## General information

- The device supports the MP Data-Pool functional profile. All available data points are managed in a data pool and accessible with MP read/write commands.
- This document describes all public data pool values of the device. It's divided into process values and configuration values.
- The MP Data-Pool functional profile is specified in the MP Cooperation Documentation. The document is provided to Belimo MP-Partners.
- See the technical datasheet for technical information about the device itself.

## Configuration

MP-Bus Configuration data are not password protected. No login is required.  
Tool Belimo Assistant 2

## Identification

The connected type can be identified by its series number:

Prefix	Profile type	Profile category	Type
2	1	36	22PF-..

## Timing of MP-Bus queries

Client implementations typically poll the servers in cycles (MP1, MP2, MP3, ...). Reading all data pool values of this node in one cycle are not recommended, because it would reduce the overall MP-Bus performance.

Recommendation:

- Split up the queries into several cycles (e.g. 3 queries per cycle).
- Adjust repetition rates (reading values) according to the rate of change of the value.
- Prevent from reading unused data pool values.

## Signed integer

Signed integers are represented as two's complement.

Example:

---

Value of ID40 = 1111 1101 1111 0010<sub>2</sub> = -526<sub>10</sub>

Actual value  
 = value \* scaling factor \* unit  
 = -526 \* 0.01 \* unit  
 = **-5.26 unit**

# Values overview

## Operation

ID	Name	Access
15	Sensor 1 Value [mV] [Ω] [-]	R
19	Relative Volumetric Flow [%]	R
20	Absolute Volumetric Flow [l/s]	R
22	Absolute Volumetric Flow [selected unit]	R
26	Glycol Concentration [%]	R
29	Temperature (flowbody) [°C]	R
51	Accumulated Volume [m³]	R

## Configuration

ID	Name	Access
110	Malfunction & Service information	R
120	Sensor 1 Type	R / W
133	FS (Full scale) [l/s]	R
151	Unit Selection Flow	R / W
200	Flow Meter Serial Number First Digits	R
201	Flow Meter Serial Number Last Digits	R

Access definition: R = Read, W = Write



All writeable datapoints with ID >100 (configuration data) are persistent and are **not** supposed to be written on a regular basis. Designated data points are highlighted in colour in the document.

# Values descriptions

## Flow

These data-pool values can be used to configure and read values related to Flow control.

No.	Description Comments	Values	Unit	Scaling	Size	Access
19	<b>Relative volumetric flow</b> Related to ID 133: "FS" (full scale)	0..15'000	%	0.01	2	R
20	<b>Absolute volumetric flow</b> Actual measurement range depends on device type (see data sheet).	0..10'416.7	l/s	0.01	2	R
22	<b>Absolute volumetric flow in selected unit</b> Actual measuring range depends on device type (see data sheet).  → Unit can be selected by ID 151: Unit selection flow.	0..104.167 0..375'000 0..104'167 0..6'250'000 0..375'000'000 0..1'651'075 0..220'716	m <sup>3</sup> /s m <sup>3</sup> /h l/s l/min l/h gpm cfm	0.001	4	R
133	<b>FS (full scale)</b> Nominal volumetric flow	0..6'250	l/s	0.01	2	R
151	<b>Unit selection flow</b> The selected unit is valid for ID 22: Absolute volumetric flow in selected unit.	0: m <sup>3</sup> /s 1: m <sup>3</sup> /h 2: l/s 3: l/min 4: l/h 5: gpm 6: cfm Default: 4	–	–	1	R / W
26	<b>Glycol concentration</b> Actual measuring range depends on device type (see datasheet).	0..6'000	%	0.01	2	R
51	<b>Accumulated volume</b> (cannot be reset)	0..21'474'836	m <sup>3</sup>	0.01	4	R
200	<b>Flow Meter serial number first digits</b>	–	–	1	4	R
201	<b>Flow Meters serial number last digits</b>	–	–	1	4	R

Definition Access: R = Read, W = Write

**Note:** According to the present configuration settings of the product (e.g. DN size) the HVAC application may perform a size limitation within the indicated MP-Bus value range. Each product may have different HVAC value size limitations.

## Temperature

The measured temperature values can be read out via the data-pool value below.

No.	Description Comments	Values	Unit	Scaling	Size	Access
29	<b>Temperature (flowbody)</b>	-2'000...12'000	°C	0.01	2	R

## Conversion of sensor signals

These data-pool values can be used to configure the additional Sensor 1 inout on Y3 and related values.

No.	Description Comments	Values	Unit	Scaling	Size	Access
15	<b>Sensor 1 value</b> Current value of sensor 1, depending on setting of ID 120: Sensor 1 type	0...65'535	mV -	1	2	R
120	<b>Sensor 1 type</b> Additional sensor input	0: None 1: Active 2: - 3: - 4: Switch	-	-	1	R / W

Definition Access: R = Read, W = Write

**Note:** According to the present configuration settings of the product (e.g. DN size) the HVAC application may perform a size limitation within the indicated MP-Bus value range. Each product may have different HVAC value size limitations.

## Health state

These data-pool values allow to determine malfunctions, service information and error states of the Flow sensor.

No.	Description Comments	Values	Unit	Scaling	Size	Access
110	<p><b>Malfunction and service information</b></p> <p>Value is bit-coded. More than one bit can be set to 1. Not all bits mentioned in the enumeration are used for this product range.</p> <p>3: Reverse flow is detected. Pump pressure too low; high resistance in the flow circuit; flushing bypass open</p> <p>6: Actual flow exceeds FS (designed nominal flow)</p> <p>7: Air in the system, error occurred during flow measurement. Water contamination, not specified fluid used.</p> <p>9: Error with embedded temperature sensor.</p> <p>11: Measured temperature and glycol concentration indicate that grease ice can build up</p> <p>12: Medium contains glycol.</p>	<p>Bitmask =</p> <p>0: -</p> <p>1: -</p> <p>2: -</p> <p>3: Reverse flow</p> <p>4: -</p> <p>5: -</p> <p>6: Flow actual exceeds FS</p> <p>7: Flow measurement error</p> <p>8: -</p> <p>9: Flowbody temperature error</p> <p>10: -</p> <p>11: Freeze warning</p> <p>12: Glycol detected</p> <p>13: -</p> <p>14: -</p> <p>15: -</p>	-	-	2	R

Definition Access: R = Read, W = Write

**Note:** According to the present configuration settings of the product (e.g. DN size) the HVAC application may perform a size limitation within the indicated MP-Bus value range. Each product may have different HVAC value size limitations.

# All inclusive.

Belimo is the global market leader in the development, production, and sales of field devices for the energy-efficient control of heating, ventilation and air-conditioning systems. The focus of our core business is on damper actuators, control valves, sensors and meters.

Always focusing on customer value, we deliver more than only products. We offer you the complete product range for the regulation and control of HVAC systems from a single source. At the same time, we rely on tested Swiss quality with a five-year warranty. Our worldwide representatives in over 80 countries guarantee short delivery times and comprehensive support through the entire product life. Belimo does indeed include everything.

The “small” Belimo devices have a big impact on comfort, energy efficiency, safety, installation and maintenance.

In short: Small devices, big impact.



5-year warranty



On site around the globe



Complete product range



Tested quality



Short delivery times



Comprehensive support



## BELIMO Automation AG

Brunnenbachstrasse 1, 8340 Hinwil, Switzerland

+41 43 843 61 11, [info@belimo.ch](mailto:info@belimo.ch), [www.belimo.com](http://www.belimo.com)

